

التعديل TC-225310-01 Amendment

يستبدل الجدول التابع للفقرة (هـ) من الجزء (ثانياً) من الملحق (1) من اللائحة الفنية الخليجية للأجهزة والمعدات الكهربائية منخفضة الجهد (وثيقة رقم: 01-142004-BD) بالآتي: -.

الجمهورية اليمنية	دولة الكويت	دولة قطر	سلطنة عمان	المملكة العربية السعودية	مملكة البحرين	دولة الإمارات العربية المتحدة	
240/415±7.5%	240/415±6%	240/415±6%	240/415±6%	127/220±5% 230/400±5% 220/380±5%	230/400±6%	230/400 +10% -6%	الجهد المقتن [الفولت]
50 Hz	50 Hz	50 Hz	50 Hz	60 Hz	50 Hz	50 Hz	التردد [هيرتز]
G/M/D	G/M/C	G	G	G	G	G/M	نوع القابسات والمقابس*
* يلزم الرجوع إلى الموقع الإلكتروني للهيئة الدولية الكهروتقنية (www.iec.ch) لمعرفة نوع القابسات والمقابس حسب رموز الجدول أعلاه. * القابسات نوع C للأجهزة ذات تصنيف العزل CLASS II فقط.							

	United Arab Emirates	Kingdom of Bahrain	Kingdom of Saudi Arabia	Sultanate of Oman	State of Qatar	State of Kuwait	Republic of Yemen
Rated Voltage [Volt]	230/400 +10% -6%	230/400±6%	127/220±5% 230/400±5% 220/380±5%	240/415±6%	240/415±6%	240/415±6%	240/415±7.5%
Frequency [Hertz]	50 Hz	50 Hz	60 Hz	50 Hz	50 Hz	50 Hz	50 Hz
Plug and Socket type*	G/M	G	G	G	G	G/M/C	G/M/D
* Plug and Socket type shall be reviewed from the IEC website www.iec.ch * Plugs type C for Class II appliances only.							